

**DELHI JAL BOARD: GOVT. OF NCT DELHI
OFFICE OF THE EXECUTIVE ENGINEER (RWH/GWC)
ROOM NO-209, VARUNALAYA PH-I,
JHANDEWALAN NEW DELHI-110005**

No.DJB/EE (RWH/GWC)/2019/ 1501

Dated:- 29/3/19

To,

Principal,
D.V.S. Public School,
25 Ft. Road, Shastri Park,
Burari, Delhi-110084

**Sub:- Adequacy certificate for RWH structure at D.V.S. Public School,
25 Ft. Road, Shastri Park, Burari, Delhi-110084.**

Sir,

Please refer to your letter dated 21.06.2018, in which you have informed that Rain Water Harvesting has been installed at your said premises, the rain water harvesting structure was inspected by NGT joint inspection team on dated 28.03.2019 and found sufficient and adequate to harvest the catchment area of your premises.

You are therefore advised to keep are RWH system neat & clean and maintain the same periodically.


EE (RWH)
EE (G W CELL)
DELHI JAL BOARD
VARUNALAYA CHAWAN,
JHANDEWALLAN, N.D.-05

RAIN WATER HARVESTING

FOR PUBLIC SCHOOLS OF ZONE VII DISTRICT NORTH ONLY

dvspublicschool@gmail.com [Switch account](#)

 Not shared

 Draft saved

* Indicates required question

SCHOOL NAME, ID & ADDRESS

D.V.S PUBLIC SCHOOL (1207256) 25Ft. road sl

NO.OF RWH STRUCTURE INSTALLED (IF EXEMPTED MUST FILL THE REST INFORMATION)

1

LATITUDE

28.76800

LONGITUDE

77.18627



TOTAL PLOT AREA (in sqm)

1685.58

ROOF TOP AREA (in sqm)

560.19

SIZE OF PIT (s) L*B*H (in mtr)

3.6*3.5*2.8

FUNCTIONAL

☒ YES☐ NO☐ N/A

Clear selection

REMARKS *

its in working condition

Submit

Clear form



Never submit passwords through Google Forms.



DELHI JAL BOARD: GNCTD
ZONAL LABORATORY WTP WAZIRABAD, DELHI-54



TEST REPORT

Sample ID	Ref. No. D.J.B/DTQC/Wzd/2025-26/Paid-160-161		
Location /Address of Sample	D.V.S Public School, 25Ft. Road, Shastri Park, Uttarakhand, Burari, Delhi-110084		
Letter Reference No.	DVSPS 2025	Ref. Letter Date	04.11.2025
Challan No.	188	Challan Date	04.11.2025
Sample Collection date	07.11.2025	Analysis start date	07.11.2025
Any other Information	--	Analysis end date	10.11.2025
		Reporting date	14.11.2025

TEST RESULTS

S.No	Parameters	Unit	As per the IS 10500		Inlet (Borewell)	Outlet (RO)
			Acceptable limit	Permissible limit		
1	Colour	CU	5(Max)	15(Max)	2.0	2.0
2	Odour	Agreeable	Agreeable	Agreeable	Agreeable	Agreeable
3	Turbidity	NTU	1	5	3.9	1.0
4	pH Value at 27 °C	--	6.5-8.5	No relaxation	7.05	6.87
5	Electrical Conductivity	µS/cm	-	-	3000	547
6	Total Dissolved Solids	mg/L	500(Max)	2000(Max)	1950	355
7	Total Alkalinity as CaCO ₃	mg/L	200(Max)	600(Max)	526	72
8	Total Hardness as CaCO ₃	mg/L	200(Max)	600(Max)	840	86
9	Calcium as Ca	mg/L	75(Max)	200(Max)	156	12
10	Magnesium as Mg	mg/L	30(Max)	100(Max)	108	13.4
11	Iron as Fe	mg/L	1.0(Max)	No relaxation	0.20	0.06
12	Chloride as Cl	mg/L	250(Max)	1000(Max)	457	104
13	Fluoride as F	mg/L	1.0(Max)	1.5(Max)	0.6	0.4
14	Ammonical-Nitrogen	mg/L	0.5(Max)	No relaxation	0.24	BDL
15	Nitrate as NO ₃	mg/L	45(Max)	No relaxation	3.9	1.6
16	Sulphate as SO ₄	mg/L	200(Max)	400(Max)	256	80
17	Residual Chlorine	mg/L	0.2(Min.)	1.0(Max)	BDL	BDL
18	Coliform Count at 37°(MPN)	/100 mL	Absent	No relaxation	210	0

*BDL=Below Detection Limit

.....End of Report.....

Remarks: Outlet Sample from drinking tap conform specification for the tested parameters and can be considered for drinking purpose.

Tested by
Lab.Tech.

Verified for Chemical parameters
Asstt.Chemist

Verified for MPN
Bacteriologist

Authorized by
Chemist

ACWA(WZD)

Asstt. Chief Water Analyst
D.J.B. (Govt. of N.C.T. of Delhi)
Water Works, Wazirabad



MUNICIPAL CORPORATION OF DELHI
(PUBLIC HEALTH DEPARTMENT: CIVIL LINES ZONE)
16, RAJ PUR ROAD, DELHI – 110054



DHO/CLZ/2025/...1561

Dated:- 15/10/25

SCHOOL HEALTH CERTIFICATE

It is certified that an inspection team headed by public health inspector Civil Lines Zone from Public Health Department, inspected the **M/S D.V.S Public School situated at 25ft. Road Shastri Park, Uttarakhand, Burari, Delhi - 110084** on 15.10.2025 and found that the school is running under sanitary and hygienic conditions from health point of view. School has safe drinking water facilities for the students and members of staff of the institution and maintaining the hygiene and sanitation condition in the school building and the campus.

The above certificate is valid for 1 year from date of issue.

Principal

M/S D.V.S.PUBLIC SCHOOL
25ft.Road Shastri Park(Uttarakhand)
Burari Delhi-110084


Dy. Health Officer
Civil Lines Zone
Deputy Health Officer
Civil Lines Zone
Municipal Corporation of Delhi
16, Rajpur Road, Delhi-110054